

This system has been tested according to NSF/ANSI 42 for reduction of the substances listed below in Table I. The concentration of the indicated substances in the water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system as specified in NSF/ANSI.

Contaminant	Influent Challenge Concentration	Reduction Requirement	Average Reduction Efficiency
<i>Standard 42 – Aesthetic Effects.</i> Taste, Odour, Chlorine Reduction	2.0 mg/L $\pm$ 10%	$\geq$ 50%	> 90%

TABLE- I

The standards referenced above evaluate performance for use with disinfected water.

All testing performed under standard laboratory conditions. Actual performance may vary.

Note: Contaminants reduced by this filter are not necessarily present in water. Individuals requiring water of specific microbiological purity should follow the advice of their doctor or local health unit.

#### Technical Specifications

Replacement filter	-	Model CF2
Rated filter life	-	6 months or 1000 US gal (3785 Liters)
Rated service flow	-	0.75 US GPM (2.83 LPM)
Inlet/Outlet connections	-	3/8" FNPT
Operating Temp	-	4°C (39°F) min. to 38°C (100°F) max.
Working Pressure	-	20 psi (137 kPa) min. to 100 psi (689 kPa) max.

General Operation & Maintenance: See product manual for maintenance instructions. User is responsible for general maintenance.

Warranty – Limited 5 year warranty. See product manual for details.

For replacement parts contact your nearest Rainfresh dealer.



Envirogard Products Limited  
446, Major Mackenzie Drive East, Richmond Hill,  
ON L4C 1J2, CANADA  
Tel: (905) 884 9388 Fax: (905) 884 3532.  
Web: [www.rainfresh.ca](http://www.rainfresh.ca)