Specification Data Panasonic Ventilation Fan



Panasonic



Ventilating fan shall be Low Noise remote mount type rated for continuous run. Fan shall be Energy Star rated and certified by the Home Ventilating Institute (HVI). Evaluated by Underwriters Laboratories and conform to both UL and cUL safety standards.

FV-40NLF1



Motor/Blower:

- Four-pole totally enclosed condenser motor rated for continuous run.
- Power Rating shall be 120 volts and 60 hz.
- Fan shall be UL listed for tub/shower enclosure when used with a GFCI branch circuit wiring.
- Motor equipped with thermal-cutoff fuse.

Housing:

- Galvanized steel body for long-life.
- Insulated housing to prevent condensation and noise.
- Tapered duct adapter for easy connection.

Easy Installation:


- 5 positions installation.
- Joist, truss and suspension brackets included.


Warranty:

The factory warranty shall be a minimum of 3 years limited warranty on parts.

Typical Specifications

Ventilating fan shall be remote mount, Energy Star rated, with no less than 440 CFM as certified by the Home Ventilating Institute (HVI) at 0.2" static pressure in inches water gauge and no more than 2.1 sone as rated by manufacturer at 0.2" static pressure. Power consumption shall be no greater than 135 watts, Energy Star rated and Energy Efficiency rating shall be no less than 3.3 cfm/watt. The motor shall be the totally enclosed, four pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz. Housing shall be insulated to reduce condensation. Duct diameter shall be no less than 4". Fan shall be UL and cUL listed for tub/shower enclosure when used with GFCI branch circuit wiring. Brackets shall be provided for joist, truss or suspension installations.





Specifications: Weight Rated Max Max CFM³ Max Duct Fan Model Volts 0"SP .2"SP .4"SP .6"SP .8"SP 1.0"SP 1.2"SP SP* Dia. Sones CFM/Watt Watt* Amps (lbs) FV-40NLF1 1110 120 1.1 1.29 Sones were measured at factory test facility in a sound-proof room at suction side from a distance of 1.5 meters





For Complete Installation Instructions Visit www.panasonic.com/building

Model	Quantity	Comments	Project:
			Location:
			Architect:
			Engineer:
			Contractor:
			Submitted by:
			Date: