


# MODEL 162M INFRARED BULB HEATER




Silent warmth and ventilation in a compact design.

### FEATURES

- White polymeric grille
- Sturdy steel housing
- Adjustable mounting brackets that span up to 24"
- Housing that can be adjusted vertically after ceiling is finished
- Uses 250 W BR40-size infrared bulb (not included)
- Plug-in, permanently lubricated motor
- Quiet polymeric blower wheel
- Polymeric damper/duct connector with 1-5/8" long tapered sleeve and no metallic clatter
- Heat and Vent functions may be controlled separately or in combination
- Suitable for use in insulated ceiling (Type I.C.)

NOTE: For installation in ceiling up to 12/12 pitch



NOTE: Dimensions shown are in inches.

### TYPICAL SPECIFICATION

Bulb heater shall be Broan model 162M. Heater shall have corrosion resistant steel housing and adjustable mounting brackets. Unit must use a 250 W BR40-size infrared bulb. Bulb heater to be CSA certified.

Motor assembly to be removable and permanently lubricated. Non-metallic damper/duct connector to be included. Heater and ventilator to operate separately (or in combination) by using an accessory control (purchase separately).

Air delivery shall be no less than 70 CFM and sound level no greater than 4.0 sones. All air and sound ratings shall be certified by HVI. Unit suitable for use in insulated ceilings (Type I.C.) up to an R40 factor.


### SPECIFICATIONS

VOLTS	AMPS	WATTS*	SONES	CFM	ROUND DUCT
120	2.5	300**	4.0	70	4"

\*Total connected load

\*\*BR40-size infrared bulbs.

Use house wiring rated 60°C minimum.



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.



Broan-NuTone Canada ULC Mississauga, Ontario Canada www.broan.ca 1-888-882-7626

REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by <span style="float: right;">Date</span>